

C.O.C.: DW 012617

REPORT No: 23-012617 - Rev. 0

Report To:

Greater Essex County District School Board
 280 Eugenie St. E
 Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories

2378 Holly Lane
 Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
 DATE REPORTED: 2023-Jun-05
 SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Kennedy North
 P.O. NUMBER:
 WATERWORKS NO: 500312352

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-Jun-05	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit

NC = Not Calculated

Test methods may be modified from specified reference method unless indicated by an *

Parameter	Units	R.L.	Limits	DWG	Client I.D.	Sample I.D.	Date Collected
					Nken-T1-S	Nken-T1-F	Nken-F2-S
Lead	mg/L	0.00002	0.010	MAC	0.00050	0.00016	0.0134
					0.00405		

DWG - Drinking Water Guidelines

ODWS - Ontario Drinking Water Standards

AO - Aesthetic Objectives

IMAC - Interim Maximum Acceptable Concentration

MAC - Maximum Acceptable Concentration

ODWO - D-5-5 Objective

OG - Operational Guidelines

WL - Warning Level - Sodium Restricted Diets

Summary of Exceedances		
Maximum Acceptable Concentration		
Nken-F2-S	Found Value	Limit
Lead	0.0134	0.010



Shelly Lozo
 Microbiology Supervisor