

C.O.C.: -

REPORT No: 23-010022 - Rev. 0

Report To:

Greater Essex County District School Board
 280 Eugenie St. E
 Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories

5-3201 Marentette Ave
 Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-09
 DATE REPORTED: 2023-May-17
 SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Queen Elizabeth
 P.O. NUMBER:
 WATERWORKS NO: 500022959

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-16	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit

NC = Not Calculated

Test methods may be modified from specified reference method unless indicated by an *

Parameter	Units	R.L.	Client I.D.	Client I.D.
			Sample I.D.	Sample I.D.
			Date Collected	Date Collected
Lead	mg/L	0.00002	0.00474	0.00262



Shelly Lozo
 Microbiology Supervisor