

C.O.C.: -

REPORT No: 23-014395 - Rev. 0

Report To:

Greater Essex County District School Board
 280 Eugenie St. E
 Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories

5-3201 Marentette Ave
 Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED: 2023-Jun-19	CUSTOMER PROJECT: Sandwich West
DATE REPORTED: 2023-Jun-28	P.O. NUMBER:
SAMPLE MATRIX: Drinking Water	WATERWORKS NO: 500022946

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-23	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit

NC = Not Calculated

Test methods may be modified from specified reference method unless indicated by an *

Parameter	Units	R.L.	Client I.D.	
			Sample I.D.	Date Collected
Lead	mg/L	0.00002	SW-T21-S	SW-T21-F
			23-014395-1	23-014395-2
			2023-06-17	2023-06-17
			-	-
			0.00333	0.00116



Lorina Merko
Laboratory Manager