

**C.O.C.: DW 012609**

**REPORT No: 23-012609 - Rev. 0**

**Report To:**

Greater Essex County District School Board  
 280 Eugenie St. E  
 Windsor, ON N8X 2X8

**CADUCEON Environmental Laboratories**

2378 Holly Lane  
 Ottawa, ON K1V 7P1

**Attention: Rachel Bondy**

DATE RECEIVED: 2023-May-31      CUSTOMER PROJECT: Sandwich West  
 DATE REPORTED: 2023-Jun-05      P.O. NUMBER:  
 SAMPLE MATRIX: Drinking Water      WATERWORKS NO: 500022933

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-Jun-05	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit  
 NC = Not Calculated  
 Test methods may be modified from specified reference method unless indicated by an \*

Parameter	Units	R.L.	Limits	DWG	Client I.D.			
					SWPS-F13-S	SWPS-F13-F	SWPS-T21-S	SWPS-T21-F
					Sample I.D.			
					Date Collected			
					Date Collected			
Lead	mg/L	0.00002	0.010	MAC	0.00054	0.00019	<b>0.0101</b>	0.00150

Lead adverse (sample #3) = 10.06 ug/L  
 Reported 23/06/05

- DWG - Drinking Water Guidelines**  
 ODWS - Ontario Drinking Water Standards  
 AO - Aesthetic Objectives  
 IMAC - Interim Maximum Acceptable Concentration  
 MAC - Maximum Acceptable Concentration  
 ODWO - D-5-5 Objective  
 OG - Operational Guidelines  
 WL - Warning Level - Sodium Restricted Diets

Summary of Exceedances		
Maximum Acceptable Concentration		
SWPS-T21-S	Found Value	Limit
Lead	0.0101	0.010

*Shelly Lozo*  
 Shelly Lozo

**Microbiology Supervisor**