

C.O.C.: -

REPORT No: 23-010881 - Rev. 0

**Report To:**

Greater Essex County District School Board  
 280 Eugenie St. E  
 Windsor, ON N8X 2X8

**CADUCEON Environmental Laboratories**

5-3201 Marentette Ave  
 Windsor, ON N8X 4G3

**Attention: Rachel Bondy**

DATE RECEIVED: 2023-May-15	CUSTOMER PROJECT: Tecumseh Vista Academy K-12
DATE REPORTED: 2023-May-26	P.O. NUMBER:
SAMPLE MATRIX: Drinking Water	WATERWORKS NO: 500269114

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	8	OTTAWA	TPRICE	2023-May-19	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit  
 NC = Not Calculated

Test methods may be modified from specified reference method unless indicated by an \*

Client I.D.	Sample I.D.	Date Collected	Parameter
			Units
			R.L.
			Lead
			mg/L
			0.00002
			-
TVA-B10-S	23-010881-1	2023-May-14	0.00007
TVA-B10-F	23-010881-2	2023-May-14	0.00012
TVA-F33A-S	23-010881-3	2023-May-14	0.00008
TVA-F33A-F	23-010881-4	2023-May-14	0.00004
TVA-B22-S	23-010881-5	2023-May-14	0.00028
TVA-B22-F	23-010881-6	2023-May-14	0.00005
TVA-B31-S	23-010881-7	2023-May-14	0.00003
TVA-B31-F	23-010881-8	2023-May-14	0.00003



**Lorina Merko**  
**Laboratory Manager**