

C.O.C.: DW 012456

REPORT No: 23-012456 - Rev. 0

Report To:

Greater Essex County District School Board
 280 Eugenie St. E
 Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories

2378 Holly Lane
 Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31	CUSTOMER PROJECT: Westview Freedom Academy
DATE REPORTED: 2023-Jun-05	P.O. NUMBER:
SAMPLE MATRIX: Drinking Water	WATERWORKS NO: 500023115

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-02	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit

NC = Not Calculated

Test methods may be modified from specified reference method unless indicated by an *

Parameter	Units	R.L.	Client I.D.	
			WFA-F31-S	WFA-F31-F
			Sample I.D.	
			23-012456-1	23-012456-2
			Date Collected	
			2023-05-27	2023-05-27
			-	-
Lead	mg/L	0.00002	0.00153	0.00065



Shelly Lozo
Microbiology Supervisor