

C.O.C.: DW 012622

REPORT No: 23-012622 - Rev. 0

Report To:

Greater Essex County District School Board
 280 Eugenie St. E
 Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories

2378 Holly Lane
 Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31	CUSTOMER PROJECT: Westview Freedom Academy
DATE REPORTED: 2023-Jun-05	P.O. NUMBER:
SAMPLE MATRIX: Drinking Water	WATERWORKS NO: 500023115

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	6	OTTAWA	TPRICE	2023-Jun-05	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit

NC = Not Calculated

Test methods may be modified from specified reference method unless indicated by an *

Parameter	Units	R.L.	Client I.D.	Client I.D.	Client I.D.	Client I.D.	Client I.D.
			Sample I.D.	Sample I.D.	Sample I.D.	Sample I.D.	Sample I.D.
			Date Collected	Date Collected	Date Collected	Date Collected	Date Collected
Lead	mg/L	0.00002	0.00167	0.00106	0.00053	0.00041	0.00010

Parameter	Units	R.L.	Client I.D.
			Sample I.D.
			Date Collected
Lead	mg/L	0.00002	0.00004

Shelly Lozo
 Shelly Lozo

Microbiology Supervisor