

C.O.C.: DW 012412

REPORT No: 23-012412 - Rev. 0

Report To:

Greater Essex County District School Board
 280 Eugenie St. E
 Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories

2378 Holly Lane
 Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
 DATE REPORTED: 2023-Jun-02
 SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: William G Davis
 P.O. NUMBER:
 WATERWORKS NO: 500023765

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-01	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit

NC = Not Calculated

Test methods may be modified from specified reference method unless indicated by an *

Parameter	Units	R.L.	Client I.D.	
			Sample I.D.	Date Collected
			DAV-B4-S	DAV-B4-F
			23-012412-1	23-012412-2
			2023-05-22	2023-05-22
			-	-
Lead	mg/L	0.00002	0.00075	0.00049



Shelly Lozo
 Microbiology Supervisor