

C.O.C.: -

REPORT No: 24-026626 - Rev. 0

Report To:

Greater Essex County District School Board
 280 Eugenie St. E
 Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories

5-3201 Marentette Ave
 Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED: 2024-Aug-28
 DATE REPORTED: 2024-Aug-30
 SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Erie Migration District School
 P.O. NUMBER:
 WATERWORKS NO: 500486461

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	22	OTTAWA	AOZKAYMAK	2024-Aug-29	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit

NC = Not Calculated

Test methods may be modified from specified reference method unless indicated by an *

Client I.D.	Sample I.D.	Date Collected	Parameter	Units	R.L.	Limits	DWG
			Lead	mg/L	0.00002	0.010	MAC
							-
B16-S	24-026626-1	2024-Aug-23					0.00034
B16-F	24-026626-2	2024-Aug-23					0.00021
B12-S	24-026626-3	2024-Aug-23					0.00061
B12-F	24-026626-4	2024-Aug-23					0.00040
T31-S	24-026626-5	2024-Aug-23					0.00104
T31-F	24-026626-6	2024-Aug-23					0.00215
T30-S	24-026626-7	2024-Aug-23					0.00159
T30-F	24-026626-8	2024-Aug-23					0.00042
B11-S	24-026626-9	2024-Aug-23					0.00028
B11-F	24-026626-10	2024-Aug-23					0.00011



Lorina Merko
 Laboratory Manager

			Parameter
			Lead
			Units
			R.L.
			Limits
			DWG
Client I.D.	Sample I.D.	Date Collected	-
T4C-S	24-026626-11	2024-Aug-23	0.00340
T4C-F	24-026626-12	2024-Aug-23	0.00123
F14-S	24-026626-13	2024-Aug-23	0.00040
F14-F	24-026626-14	2024-Aug-23	0.00028
B25-S	24-026626-15	2024-Aug-23	0.00037
B25-F	24-026626-16	2024-Aug-23	0.00034
F20-S	24-026626-17	2024-Aug-23	0.00038
F20-F	24-026626-18	2024-Aug-23	0.00041
F19-S	24-026626-19	2024-Aug-23	0.00051
F19-F	24-026626-20	2024-Aug-23	0.00018
B3-S	24-026626-21	2024-Aug-23	0.00015
B3-F	24-026626-22	2024-Aug-23	0.00013

DWG - Drinking Water Guidelines
 ODWS - Ontario Drinking Water Standards
 AO - Aesthetic Objectives
 IMAC - Interim Maximum Acceptable Concentration
 MAC - Maximum Acceptable Concentration
 ODWO - D-5-5 Objective
 OG - Operational Guidelines
 WL - Warning Level - Sodium Restricted Diets


 Lorina Merko
 Laboratory Manager