

C.O.C.: -

REPORT No: 24-026682 - Rev. 0

Report To:

Greater Essex County District School Board
 280 Eugenie St. E
 Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories

5-3201 Marentette Ave
 Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED: 2024-Aug-29
 DATE REPORTED: 2024-Sep-03
 SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Erie Migration District School
 P.O. NUMBER:
 WATERWORKS NO: 500486461

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	8	OTTAWA	AOZKAYMAK	2024-Sep-03	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit

NC = Not Calculated

Test methods may be modified from specified reference method unless indicated by an *

Client I.D.	Sample I.D.	Date Collected	Parameter	Units	R.L.	Limits	DWG
			Lead	mg/L	0.00002	0.010	MAC
							-
T5A-S	24-026682-1	2024-Aug-29					0.00201
T5A-F	24-026682-2	2024-Aug-29					0.00134
T3-S	24-026682-3	2024-Aug-29					0.00183
T3-F	24-026682-4	2024-Aug-29					0.00071
B17-S	24-026682-5	2024-Aug-29					0.00241
B17-F	24-026682-6	2024-Aug-29					0.00042
T28-S	24-026682-7	2024-Aug-29					0.00069
T28-F	24-026682-8	2024-Aug-29					0.00011



Lorina Merko
 Laboratory Manager

DWG - Drinking Water Guidelines

ODWS - Ontario Drinking Water Standards

AO - Aesthetic Objectives

IMAC - Interim Maximum Acceptable Concentration

MAC - Maximum Acceptable Concentration

ODWO - D-5-5 Objective

OG - Operational Guidelines

WL - Warning Level - Sodium Restricted Diets



Lorina Merko
Laboratory Manager