

C.O.C.: -

REPORT No: 24-017468 - Rev. 0

Report To:

Greater Essex County District School Board
 280 Eugenie St. E
 Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories

2378 Holly Lane
 Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2024-Jun-13 CUSTOMER PROJECT: Kingsville Public School
 DATE REPORTED: 2024-Jun-14 P.O. NUMBER:
 SAMPLE MATRIX: Drinking Water WATERWORKS NO: 500022803

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	AOZKAYMAK	2024-Jun-13	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit

NC = Not Calculated

Test methods may be modified from specified reference method unless indicated by an *

Parameter	Units	R.L.	Client I.D.	
			KPS-B12-S	KPS-B12-F
			Sample I.D.	
			24-017468-1	24-017468-2
			Date Collected	
			2024-05-25	2024-05-25
			-	-
Lead	mg/L	0.00002	0.00082	0.00051



Shelly Lozo
 Microbiology Supervisor