

C.O.C.: -

REPORT No: 24-013177 - Rev. 0

**Report To:**

Greater Essex County District School Board  
 280 Eugenie St. E  
 Windsor, ON N8X 2X8

**CADUCEON Environmental Laboratories**

2378 Holly Lane  
 Ottawa, ON K1V 7P1

**Attention: Rachel Bondy**

DATE RECEIVED: 2024-May-09      CUSTOMER PROJECT: Leamington District Secondary School  
 DATE REPORTED: 2024-May-10      P.O. NUMBER:  
 SAMPLE MATRIX: Drinking Water      WATERWORKS NO: 500436216

| Analyses        | Qty | Site Analyzed | Authorized | Date Analyzed | Lab Method | Reference Method |
|-----------------|-----|---------------|------------|---------------|------------|------------------|
| ICP/MS (Liquid) | 6   | OTTAWA        | AOZKAYMAK  | 2024-May-10   | D-ICPMS-01 | EPA 200.8        |

R.L. = Reporting Limit

NC = Not Calculated

Test methods may be modified from specified reference method unless indicated by an \*

| Parameter | Units | R.L.    | Client I.D.    | LDHS-T2-S   | LDHS-T2-F   | LDHS-F11-S  | LDHS-F11-F  | LDHS-T27-S  |
|-----------|-------|---------|----------------|-------------|-------------|-------------|-------------|-------------|
|           |       |         | Sample I.D.    | 24-013177-1 | 24-013177-2 | 24-013177-3 | 24-013177-4 | 24-013177-5 |
|           |       |         | Date Collected | 2024-05-04  | 2024-05-04  | 2024-05-04  | 2024-05-04  | 2024-05-04  |
| Lead      | mg/L  | 0.00002 |                | 0.00024     | 0.00010     | 0.00003     | 0.00014     | 0.00034     |

| Parameter | Units | R.L.    | Client I.D.    | LDHS-T27-F  |
|-----------|-------|---------|----------------|-------------|
|           |       |         | Sample I.D.    | 24-013177-6 |
|           |       |         | Date Collected | 2024-05-04  |
| Lead      | mg/L  | 0.00002 |                | 0.00018     |

*Shelly Lozo*  
 Shelly Lozo

**Microbiology Supervisor**