

C.O.C.: -

REPORT No: 24-014787 - Rev. 0

Report To:

Greater Essex County District School Board
 280 Eugenie St. E
 Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories

2378 Holly Lane
 Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2024-May-23	CUSTOMER PROJECT: Riverside Secondary School
DATE REPORTED: 2024-May-27	P.O. NUMBER:
SAMPLE MATRIX: Drinking Water	WATERWORKS NO: 500023778

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	6	OTTAWA	TPRICE	2024-May-27	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
 NC = Not Calculated
 Test methods may be modified from specified reference method unless indicated by an *

Parameter	Units	R.L.	Client I.D.	Sample I.D.	Date Collected	Units	R.L.
			RSS-T18-S	RSS-T18-F	RSS-B26-S	RSS-B26-F	RSS-B29-S
				24-014787-1	2024-05-18		
				24-014787-2	2024-05-18		
				24-014787-3	2024-05-18		
				24-014787-4	2024-05-18		
				24-014787-5	2024-05-18		
Lead	mg/L	0.00002	0.00008	0.00006	<0.00002	<0.00002	0.00005

Parameter	Units	R.L.	Client I.D.	Sample I.D.	Date Collected	Units	R.L.
			RSS-B29-F	24-014787-6	2024-05-18		
Lead	mg/L	0.00002	0.00004				

Shelly Lozo
 Shelly Lozo

Microbiology Supervisor